



Evaluation Listing CCMC 14022-L RockWool Premium Plus™

Evaluation Issued: 2015-09-01
Revised: 2016-05-25
Re-evaluation due: 2018-09-01

Preface: Masterformat 07 21 23.07, Loose-Fill Mineral-Fibre Thermal Insulation

Preface Issued: 2012-08-31

Scope

These Evaluation Listings apply to mineral-fibre thermal insulation when used in unconfined spaces with slopes not exceeding 4.5:12. The proponent has demonstrated that the product meets the following standard:

- CAN/ULC-S702-09, "Standard for Mineral Fibre Thermal Insulation for Buildings."

The standard describes five types of mineral-fibre insulation. These CCMC Evaluation Listings refer only to loose-fill insulation, Types 4 and 5, which are defined as follows:

- Type 4, pouring wool – loose-fill mineral-fibre insulation subdivided into nodules, suitable for manual application or pouring (reassigned in CAN/ULC-S702-09, Amendment 1);
- Type 5, blowing wool – loose-fill mineral-fibre insulation subdivided into nodules, suitable for manual application by means of pneumatic equipment.

Mineral-fibre thermal insulation must be installed in accordance with ULC-S702.2-10, "Mineral Fibre Thermal Insulation for Buildings, Part 2: Installation."

Standard

Table 1. Physical Property Requirements of Loose-Fill Mineral-Fibre Insulation

Test/Property	Requirement
Design density	\leq the limiting design density (Type 5 only)
Thermal resistivity ((m·k)W)	$\geq 18.5/m$
Surface burning characteristics	Flame spread rating ≤ 25 Smoke developed classification ≤ 50
Smoulder resistance (%)	Mean mass loss ≤ 5 , mass loss of each specimen ≤ 10
Corrosiveness	Specimen corrosion \leq control specimen
Fungi resistance	Growth \leq comparative item

Marking

The standard requires that packaging for the insulation be identified with, as a minimum:

- the brand name and the name of the manufacturer or supplier;
- identification of the manufacturing facility location;
- type of insulation and its intended use;
- net contents of the package in kg;
- date of manufacture or shift code;
- thermal resistivity of the product;
- application chart as per standard;
- any additional information required by applicable acts and regulations;
- any necessary user safety information;
- statement that the product complies with the standard;
- a cautionary statement as follows: **“Building, electrical, fire and other applicable codes shall be complied with. All heat-emitting devices, such as fuel-burning appliances, chimneys, pipes, ducts and vents to these appliances shall maintain a minimum distance of 50 mm between these devices and the insulation. Recessed light fixtures, unless designed for the purpose, shall not be installed in insulated ceilings”**; and
- CCMC Listing number.

National Building Code of Canada (NBC)

NBC References

CAN/ULC-S702-09 is referenced in Tables 5.10.1.1. and 9.23.17.2.A. and Clause 9.25.2.2.(1)(d) of Division B of the NBC 2010.

CAN/ULC-S702.2-10 is not referenced in the NBC 2010.

Evaluation Listing CCMC 14022-L: RockWool Premium Plus™

Evaluation Issued: 2015-09-01

Revised: 2016-05-25

Re-evaluation due: 2018-09-01

1. Evaluation

The product conforms to CAN/ULC-S702-09, Type 5. The measured thermal resistivity is 19.4 m²·K/W at a design density of 8.5 kg/m³.

The product must be installed as outlined in the Preface in unconfined spaces with slopes not exceeding 4.5:12 and according to the following application chart:

RSI (m ² ·K/W)	Minimum Installed Thickness (mm)	Minimum Mass per Unit Area (kg/m ²)	Maximum Coverage per 14.5-kg Bag (m ²)
1.4	72	0.61	23.8
1.8	93	0.78	18.5
2.1	109	0.91	15.9
2.8	145	1.22	11.9
3.5	181	1.52	9.5
4.2	217	1.82	7.9
4.9	253	2.13	6.8
5.3	274	2.30	6.3
5.6	290	2.43	6.0
6.3	326	2.74	5.3
7.0	362	3.04	4.8
7.7	398	3.34	4.3
8.4	434	3.65	4.0
8.8	455	3.82	3.8
9.1	471	3.95	3.7
9.8	507	4.26	3.4
10.5	543	4.56	3.2

2. Description

The product is composed of molten rock and slag which is spun to form a fibrous blowing insulation. The product is designed for pneumatic application using commercially available blowing equipment.

3. Standard and Regulatory Information

See the [Preface](#) and the standard for explanation.

Listing Holder

American Rockwool Manufacturing, LLC
1316 Village Creek Drive, Suite 600
Plano, TX 75093
U.S.A.

Telephone: 1-877-247-5970

Fax: 972-468-9086

Email: sales@americanrockwool.com
Techsupport@americanrockwool.com

Web: www.americanrockwool.com

Plant(s)

Nolanville, TX, U.S.A.

Disclaimer

This Listing is issued by the Canadian Construction Materials Centre, a program of NRC Construction at the National Research Council of Canada. The Listing must be read in the context of the entire CCMC Registry of Product Evaluations.

Readers must confirm that the Listing is current and has not been withdrawn or superseded by a later issue. Please refer to http://www.nrc-cnrc.gc.ca/eng/solutions/advisory/ccmc_index.html, or contact the Canadian Construction Materials Centre, NRC Construction, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone (613) 993-6189. Fax (613) 952-0268.

NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Listing are directed to those who have the appropriate degree of experience to use and apply its contents. This Listing is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Listing. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.

Date modified:
2016-05-25