

ProCoat Products, Inc.

Ceiling Restoration - Walgreens Store #3162

Miami Beach, FL

Light Reflectance Meter Results

Store was sprayed on January 15-16, 2012

LOCATION IN THE STORE	BEFORE CEILING RESTORATION (FC'S)	AFTER CEILING RESTORATION (FC'S)
At Entrance	90.4	119.9
At Photo	114.2	150.7
At Pharmacy	97.7	126.9
At Mirrored Area	93.4	118.5
At Center Aisle	88.3	99.7

Overall Increase of 26.9%

Notes:

1. No sunlight at times of readings.
2. Readings are affected by varied reflective surfaces nearby.